

## DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: SANDPOINT, CITY OF

ADDRESS: 1123 LAKE STREET  
SANDPOINT, ID 83864

FACILITY: CITY OF SANDPOINT - SAND CREEK WTP

LOCATION: 951 SCHWEITZER BASIN ROAD  
SANDPOINT, ID 83864

ATTN: KODY VAN DYK, PUB. WORKS DIR.

ID0024350	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
11/01/2013	11/30/2013

DMR Mailing ZIP CODE: 83864

MINOR

(SUBR 01)

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	5			Weekly	GRAB
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	deg C		Weekly	GRAB
Turbidity	SAMPLE MEASUREMENT	*****	*****	*****	*****	1.76	1.76			Monthly	GRAB
00070 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	NTU		Monthly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	7.2	*****	7.2			Weekly	GRAB
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	.84	3.84		*****	6	6			Monthly	GRAB
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	20 MO AVG	29 DAILY MX	lb/d	*****	30 MO AVG	45 DAILY MX	mg/L		Monthly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	16712	76769		*****	*****	*****	*****		Daily	METER
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Daily	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT	.004	.019		*****	.03	.03			Weekly	GRAB
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	.65 MO AVG	.65 DAILY MX	lb/d	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMIT LIMIT FOR CHLORINE = 0.007 MO AV; 0.013 DA MX FOR LBS/DY. 0.01 MO AV; 0.02 DA MX FOR MG/L.

## DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: SANDPOINT, CITY OF

ADDRESS: 1123 LAKE STREET  
SANDPOINT, ID 83864

FACILITY: CITY OF SANDPOINT - SAND CREEK WTP

LOCATION: 951 SCHWEITZER BASIN ROAD  
SANDPOINT, ID 83864

ATTN: KODY VAN DYK, PUB. WORKS DIR.

ID0024350	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
12/01/2013	12/31/2013

DMR Mailing ZIP CODE: 83864

MINOR

(SUBR 01)

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	deg C		Weekly	GRAB
Turbidity	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI C	NODI C				
00070 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	NTU		Monthly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	20 MO AVG	29 DAILY MX	lb/d	*****	30 MO AVG	45 DAILY MX	mg/L		Monthly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	NODI C	NODI C		*****	*****	*****	*****			
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Daily	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	.65 MO AVG	.65 DAILY MX	lb/d	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMIT LIMIT FOR CHLORINE = 0.007 MO AV; 0.013 DA MX FOR LBS/DY. 0.01 MO AV; 0.02 DA MX FOR MG/L.

## DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: SANDPOINT, CITY OF

ADDRESS: 1123 LAKE STREET  
SANDPOINT, ID 83864

FACILITY: CITY OF SANDPOINT - SAND CREEK WTP

LOCATION: 951 SCHWEITZER BASIN ROAD  
SANDPOINT, ID 83864

ATTN: KODY VAN DYK, PUB. WORKS DIR.

ID0024350	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
01/01/2014	01/31/2014

DMR Mailing ZIP CODE: 83864

MINOR

(SUBR 01)

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI C				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	deg C		Weekly	GRAB
Turbidity	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI C	NODI C				
00070 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	NTU		Monthly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI C	*****	NODI C				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	20 MO AVG	29 DAILY MX	lb/d	*****	30 MO AVG	45 DAILY MX	mg/L		Monthly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	0	0		*****	*****	*****	*****		Daily	METER
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Daily	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT	NODI C	NODI C		*****	NODI C	NODI C				
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	.65 MO AVG	.65 DAILY MX	lb/d	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	AREA Code	NUMBER

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMIT LIMIT FOR CHLORINE = 0.007 MO AV; 0.013 DA MX FOR LBS/DY. 0.01 MO AV; 0.02 DA MX FOR MG/L.

## DISCHARGE MONITORING REPORT (DMR)

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

NAME: SANDPOINT, CITY OF

ADDRESS: 1123 LAKE STREET  
SANDPOINT, ID 83864

FACILITY: CITY OF SANDPOINT - SAND CREEK WTP

LOCATION: 951 SCHWEITZER BASIN ROAD  
SANDPOINT, ID 83864

ATTN: KODY VAN DYK, PUB. WORKS DIR.

ID0024350	001-A
PERMIT NUMBER	DISCHARGE NUMBER
MONITORING PERIOD	
MM/DD/YYYY	MM/DD/YYYY
02/01/2014	02/28/2014

DMR Mailing ZIP CODE: 83864

MINOR

(SUBR 01)

External Outfall

No Discharge ☐

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS			
Temperature, water deg. centigrade	SAMPLE MEASUREMENT	*****	*****	*****	*****	*****	NODI E				
00010 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	*****	Req. Mon. DAILY MX	deg C		Weekly	GRAB
Turbidity	SAMPLE MEASUREMENT	*****	*****	*****	*****	NODI E	NODI E				
00070 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	*****	Req. Mon. MO AVG	Req. Mon. DAILY MX	NTU		Monthly	GRAB
pH	SAMPLE MEASUREMENT	*****	*****	*****	NODI E	*****	NODI E				
00400 1 0 Effluent Gross	PERMIT REQUIREMENT	*****	*****	*****	6.5 INST MIN	*****	9 INST MAX	SU		Weekly	GRAB
Solids, total suspended	SAMPLE MEASUREMENT	NODI E	NODI E		*****	NODI E	NODI E				
00530 1 0 Effluent Gross	PERMIT REQUIREMENT	20 MO AVG	29 DAILY MX	lb/d	*****	30 MO AVG	45 DAILY MX	mg/L		Monthly	GRAB
Flow, in conduit or thru treatment plant	SAMPLE MEASUREMENT	19532	83691		*****	*****	*****	*****		Daily	METER
50050 1 0 Effluent Gross	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	gal/d	*****	*****	*****	*****		Daily	ESTIMA
Chlorine, total residual	SAMPLE MEASUREMENT	NODI E	NODI E		*****	NODI E	NODI E				
50060 1 0 Effluent Gross	PERMIT REQUIREMENT	.65 MO AVG	.65 DAILY MX	lb/d	*****	.1 MO AVG	.1 DAILY MX	mg/L		Weekly	GRAB

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA Code
				MM/DD/YYYY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

PERMIT LIMIT FOR CHLORINE = 0.007 MO AV; 0.013 DA MX FOR LBS/DY. 0.01 MO AV; 0.02 DA MX FOR MG/L.